

88-copies of Valid Health, water and Sanitation Certificate.



MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

TEST - REPORT

Not for legal use

Ref. No. & Date Issued to : No. SGHSSPS/2024 dated 02.05.2024

Quantity of sample : ✓ The Principal,
Sri Guru Harkrishan Sr. Sec. Public School,
Sector - 40 - C, Chandigarh

Date of Collection : Approximate 1200 ml.

Client reference : 03-05-2024

Packing of sample : Sample Collected by Laboratory Staff

Source of sample : Sample filled in P.P. and Glass Bottle
from School tap of Sri Guru Harkrishan Sr. Sec. School,
Sector - 40 - C, Chandigarh

S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	-----	7.76
2	Odour	Agreeable	-----	Agreeable
3	Taste	Agreeable	-----	Agreeable
4	Turbidity	< 1.0	mg/l	0.8
5	Residual Chlorine	0.2 - 0.4	mg/l	0.3
6	Total Alkalinity (as CaCO3)	< 200	mg/l	92
7	Total Hardness (as CaCO3)	< 200	mg/l	80
8	Chloride (as Cl)	< 250	mg/l	04
9	Free & Saline Ammonia	Nil	mg/l	NIL
10	Total Dissolved Solids	< 500	mg/l	136
11	M.P.N. of Coliform Bacilli Per 100ml of water	Zero	M.P.N.	0


(Excellent)

Payment received vide receipt No.05/2024-25/191481, dated 02.05.2024, Amount Rs.3300/-

Note:- Water is fit for drinking

Lab No.- MCPH/24/ 1670


Dated:- 06.05.2024


 Chemist
 M.C.P.H. Laboratory
 Chandigarh


 Sub Divisional Engineer,
 M.C.P.H. Sub Division No.1
 Chandigarh
 Dated :- 06.05.2024

Endst No. MCPH/24/.....
 Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh
 with reference to your letter Endst No.MOH/Supdt. Admn/2024/5031 Dated 23.04.2024


 emist
 C.P.H. Laboratory
 andigarh


 Sub Divisional Engineer,
 M.C.P.H. Sub Division No.1
 Chandigarh

Digitally signed by admin
 Date: 2024.06.26 19:34:41 +05:30
 Reason: reason
 Location: location