



MUNICIPAL CORPORATION CHANDIGARH

(Public Health Laboratory at Water Works Sector - 39)

TEST - REPORT

Not for legal use

Date : 24.11.2025

Lab No. : MCPHL/25/3487

Ref. No. : SGHSSPS40/2025	Sample Details	Date & Time
Dated : 01.11.2025	Collected By : Laboratory Staff	20.11.2025
Issued to : The Principal Sri Guru Harkrishan Sr. Sec. Public School, Sec-40,C, chd	Collection Date : 06:50 a.m.	09:30 a.m.
Location : From School tap Sri Guru Harkrishan Sr. Sec. Public School, Sec-40,C, chd	Received at Lab :	
Packing : Polypropylene and glass bottle		

Test Result (As Per BIS 10500:2012)

S.No	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	---	7.73
2	Odour	Agreeable	---	Agreeable
3	Taste	Agreeable	---	Agreeable
4	Turbidity	<1	N.T.U.	0.7
5	Total Dissolved Solids	<500	mg/l	140
6	Residual Chlorine	0.2 - 0.4	mg/l	0.2
7	Total Alkalinity (as CaCO ₃)	<200	mg/l	88
8	Total Hardness (as CaCO ₃)	<200	mg/l	82
9	Chlorides (as Cl)	<250	mg/l	04
10	Free & Saline Ammonia	NIL	mg/l	NIL
11	M.P.N. of Coliform Bacilli / 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No. 11/2025-26/286548, dated 19.11.2025, amount Rs.-3300/-

Note: - Water sample is found "POTABLE"

[Signature]
Chemist
M.C.P.H. Laboratory,
Chandigarh.

[Signature]
Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Endst. No. MCPH/25/-----

Dated : 24.11.2025

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector -17, Chandigarh for Information please.

[Signature]
Chemist,
M.C.P.H. Laboratory,
Chandigarh.

[Signature]
Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Remarks:-

- The results given above are related to the sample as collected and tested in lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.

PRINCIPAL

Sri Guru Harkrishan Sr. Sec. Public School
(CHIEF KHALSA DIWAN)

[Signature]
President,

Sri Guru Harkrishan Pub. School,
(Chief Khalsa Dewan)

----- End of Report -----